
Prüfzertifikat
Test Certificate

Zertifikatnr. / *Certificate no.:* 3011446
Ausstellungsdatum / *Date of issue:* 2021-02-26

Dokumentnr. / *Document no.:* 10042182_000_00
Ersteller / *Creator:* SEGE4858

Produkt / *Product*: MV-Klemme
MV Terminal
Typ / *Type*: MMVK 3.5 8.10 SKM8X30 V4A
Artikel-Nr. / *Part No.*: 540 271
Mat.-Nr. / *Mat.-No.*: 3011446
Material: NIRO V4A



Unverbindliche Darstellung
Non-binding figure

Prüfstandard *Test standard*
IEC 62561-1 (2017)
DIN EN 62561-1 (2017)

Für statisch mechanische Last (900 N) ☐ Ja / *Yes* ☒ Nein / *No*
Withstand static mechanical load:

Anwendung: oberirdisch / *application: aboveground*

Anordnung *Arrangement*	Leiter 1 *Conductor 1 in mm*	Leiter 2 *Conductor 2 in mm*	Anzugsdrehmoment *Tightening torque in Nm*	Blitzstromklasse *Lightning current Class*
Parallel	Rd, 3, NIRO V4A	Rd, 3, NIRO V4A	M8, 10	25 kA
Parallel	Rd, 4, NIRO V4A	Rd, 4, NIRO V4A	M8, 10	25 kA
Parallel	Rd, 3, NIRO V4A	Rd, 10, NIRO V4A	M8, 10	25 kA
Parallel	Rd, 4, NIRO V4A	Rd, 10, NIRO V4A	M8, 10	25 kA
Parallel	Rd, 3, NIRO V4A	Rd, 10, St/tZn	M8, 10	25 kA
Parallel	Rd, 4, NIRO V4A	Rd, 10, St/tZn	M8, 10	25 kA
Kreuz / Cross	Rd, 3, NIRO V4A	Rd, 3, NIRO V4A	M8, 10	25 kA
Kreuz / Cross	Rd, 4, NIRO V4A	Rd, 4, NIRO V4A	M8, 10	25 kA
Kreuz / Cross	Rd, 3, NIRO V4A	Rd, 10, NIRO V4A	M8, 10	25 kA
Kreuz / Cross	Rd, 4, NIRO V4A	Rd, 10, NIRO V4A	M8, 10	25 kA
Kreuz / Cross	Rd, 3, NIRO V4A	Rd, 10, St/tZn	M8, 10	25 kA
Kreuz / Cross	Rd, 4, NIRO V4A	Rd, 10, St/tZn	M8, 10	25 kA

Prüfzertifikat
Test Certificate

Zertifikatnr. / *Certificate no.:* 3011446
Dokumentnr. / *Document no.:* 10042182_000_00
Ausstellungsdatum / *Date of issue:* 2021-02-26
Ersteller / *Creator:* SEGE4858

Das Produkt hat die Prüfung(en) in der (den) entsprechenden Anordnung(en) bestanden und kann für das Blitzschutzsystem nach IEC / EN 62305 eingesetzt werden.
The product passed the test(s) with the corresponding arrangement(s) and can be used for lightning protection systems according to IEC / EN 62305.

Alle unsere Komponenten werden in unserem Umwelt- und Qualitätsmanagement untersucht und geprüft, welches nach DIN EN ISO 14001 und DIN EN ISO 9001 zertifiziert ist.
All of our components are examined and tested in accordance with our environmental management system and quality management system which is certified based on DIN EN ISO 14001 and DIN EN ISO 9001.

Bemerkung / *remark:*

Das Anzugsdrehmoment der verwendeten Schrauben kann voneinander abweichen.
The tightening torque of the used screws can be different.
in Anlehnung an die DIN EN 62561-1, mit 25kA Blitzstoßstrom belastet.
Based on DIN EN 62561-1, tested with 25kA lightning impulse.

DEHN SE + Co KG

Complied by Siegfried Seger

Approved by Dr.-Ing. Ralph Brocke
Director R&D

Legende / *Key:*

Rd	Rundleiter / *Round conductor*	FL	Flachleiter / *Flat conductor*
Arm. / *Rein.*	Armierung / *Reinforcement*	Gew. / *Thread*	Gewindestange / *Threaded rod*
Inst.	Metallische Installation / *Metal installation*	U-Prof.	U-Profil / *U profile*
St	Stahl / *Steel*	Al	Aluminium
St/tZn	Stahl, verzinkt / *Steel, hot dip galvanized*	NIRO / *StSt*	Edelstahl / *Stainless Steel*
Cu	Kupfer / *Copper*		