Prüfzertifikat
Test Certificate

Ausstellungsdatum / *Date of issue*: 04.11.2026

DIS No.: 10043009_000_02
Ersteller / Creator: RIE41719

Produkt: HVI power long sw, D27, mehrdr, VPE:100m
Product: *HVI power long bl, D27, stranded, VPE:100m*

Artikel - Nr. / *Part- No.*: 819137

Mat. - Nr. / *Mat. - No.*: 67464



Unverbindliche Darstellung / *Non-binding figure*

Prüfstandard ***Test standard***
IEC 62561-8:2026-06
IEC 62561-8:2026-06

Normteil ***Standard***	**Anforderung** ***Requirement***	**Wert** ***Value***	**Ergebnis** ***Result***
5.5.7.1	Blitzstromtragfähigkeit *Lightning current carrying capability*	200kA	bestanden *pass*
5.5.7.2	Äquivalenter Trennungsabstand s_e *Equivalent separation distance s_e*	≤ 90 cm "Luft"; ≤ 180 cm "Feststoff" ≤ 90 cm "air"; ≤ 180 cm "solid material"	bestanden *pass*

Das Produkt hat die relevante(n) Prüfung(en) in der (den) entsprechenden Anordnung(en) bestanden und kann für das Blitzschutzsystem nach IEC / EN 62305 eingesetzt werden.
The product passed the relevant test(s) with the corresponding arrangement(s) and can be used for lightning protection systems according to IEC / EN 62305.

Alle unsere Komponenten werden in unserem Umwelt- und Qualitätsmanagement untersucht und geprüft, welches nach DIN EN ISO 14001 und DIN EN ISO 9001 zertifiziert ist.
All of our components are examined and tested in accordance with our environmental management system and quality management system which is certified based on DIN EN ISO 14001 and DIN EN ISO 9001.

DEHN SE
Hans-Dehn-Str. 1
92318 Neumarkt
Germany

i.A. M. Riel

i.A. Marijana Riel
Series Support LP&E Solutions

i.A. L. Beck

i.A. Lukas Beck
Head of Series Support LP&E Solutions