# Prüfzertifikat
# *Test Certificate*

Ausstellungsdatum / *Date of issue*: 29.10.2026

DIS No.: 10052620_000_01
Ersteller / Creator: RIE41719

Produkt: HVI light plus, gr, D21 500m, SC
*Product*: *HVI light plus, gr, D21 500m, SC*

Artikel - Nr. / *Part- No.*: 819605

Mat. - Nr. / *Mat. - No.*: 3017956



Unverbindliche Darstellung / *Non-binding figure*

| **Prüfstandard**<br>***Test standard*** |
|---|
| IEC 62561-8:2026-06 |
| *IEC 62561-8:2026-06* |

| **Normteil**<br>***Standard*** | **Anforderung**<br>***Requirement*** | **Wert**<br>***Value*** | **Ergebnis**<br>***Result*** |
|---|---|---|---|
| 5.5.7.1 | Blitzstromtragfähigkeit<br>*Lightning current carrying capability* | H1 150 kA (10/350µs) | bestanden<br>*pass* |
| 5.5.7.2 | Äquivalenter Trennungsabstand $s_e$<br>*Equivalent separation distance $s_e$* | ≤ 60 cm "Luft"; ≤ 120 cm "Feststoff"<br>≤ 60 cm "air"; ≤ 120 cm "solid material" | bestanden<br>*pass* |

Das Produkt hat die relevante(n) Prüfung(en) in der (den) entsprechenden Anordnung(en) bestanden und kann für das Blitzschutzsystem nach IEC / EN 62305 eingesetzt werden.
*The product passed the relevant test(s) with the corresponding arrangement(s) and can be used for lightning protection systems according to IEC / EN 62305.*

Alle unsere Komponenten werden in unserem Umwelt- und Qualitätsmanagement untersucht und geprüft, welches nach DIN EN ISO 14001 und DIN EN ISO 9001 zertifiziert ist.
*All of our components are examined and tested in accordance with our environmental management system and quality management system which is certified based on DIN EN ISO 14001 and DIN EN ISO 9001.*

**DEHN SE**
**Hans-Dehn-Str. 1**
**92318 Neumarkt**
**Germany**

i.A. Marijana Riel
Series Support LP&E Solutions

i.A. Lukas Beck
Head of Series Support LP&E Solutions