Certificate of Compliance

Certificate: 80066010 **Master Contract:** 215727

Project: 80066010 **Date Issued:** 2021-02-16

Issued to: Dehn SE + Co KG
Hans-Dehn-Strasse 1
92318 Neumarkt
GERMANY

Attention: Christian Frey

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only

Issued by: Robert Boede
Robert Boede

PRODUCTS

CLASS 2252 06 – PROCESS CONTROL EQUIPMENT
CLASS 2252 86 – PROCESS CONTROL EQUIPMENT – (Certified to U.S. Standards.)

Protector-Series consists of following samples:

- DRC IRCM,
- DRC IRCM TX RX,
- DRC IRCM RU

Rated: Uin 6 to 35 V d.c. / Iin max. 10 mA / CLASS III / -30°C to +70°C / PD2

© 2018 CSA Group. All rights reserved.

Certificate: 80066010 **Master Contract:** 215727
Project: 80066010 **Date Issued:** 2021-02-16

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-12,	-Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements.
- CAN/CSA-C22.2 No. 61010-2-201:18	-Safety requirements for Electrical Equipment for measurement, control, and laboratory use – Part 2-201: Particular requirements for control equipment.
- UL 61010-1, (3rd Edition)	-Safety Requirements for Electrical Equipment for Measurement, Control, an Laboratory Use – Part 1: General Requirements.
- UL 61010-2-201; (Edition 2)	-Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-201: Particular Requirements for control equipment.

Conditions of Acceptability:

1. The modules shall only be installed, operated and serviced by qualified personal.
2. The device shall be supplied by a certified power supply unit, with an output voltage of 24 VDC and which outputs fulfil the requirements of 6.3.1/6.3.2 and 9.4 of CAN/CSA-C22.2 No. 61010-1-12.

MARKINGS

See report

© 2018 CSA Group. All rights reserved.