CERTIFICATE

Issued to:
Applicant:
DEHN SE
Hans-Dehn-Str. 1
92318 Neumarkt, Germany

Licensee:
DEHN SE
Hans-Dehn-Str. 1
92318 Neumarkt, Germany

Product : surge protective devices
Trade name(s) : DEHN
Type(s)/model(s) : DG MP YPV 1200 FM and DG MP YPV 1500 FM

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:
- a type test according to EN 61643-31:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6066552

DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 22 November 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-150167

DEKRA Certification B.V.

B.T.M. Holtus
Managing Director

H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL

PRODUCTS
RvA C 001

71-150167

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra.nl Company registration 09085396

DEKRA Mark is the new KEMA-KEUR
The DEKRA Mark certificate for this product is to all intents and purposes equivalent to a KEMA-KEUR certificate, the other certification mark used by DEKRA and should be valued and used as such. DEKRA Mark is gradually replacing KEMA-KEUR.
For more information please check: Introducing DEKRA Mark

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	surge protective devices
Trade name(s)	:	DEHN
Type(s)/model(s)	:	DG MP YPV 1200 FM and DG MP YPV 1500 FM
SPD type (Test class)	:	Type 2 (II)
Maximum discharge current (Imax)	:	40 kA
Total discharge current (ITotal)	:	40 kA
Short-circuit current rating (Iscpv)	:	10 kA
Modes of protection	:	+/-, +/PE, -/PE

Product data – type DG MP YPV 1200 FM

Part number	:	942565 (with remote contact)
Maximum continuous operating voltage (Ucpv)	:	1170 V
Nominal discharge current (In)	:	20 kA
Voltage protection level (Up)	:	4,0 kV
Plug-in module	:	DG MOD H PV 600 (952048)

Product data – type DG MP YPV 1500 FM

Part number	:	942567 (with remote contact)
Maximum continuous operating voltage (Ucpv)	:	1500 V
Nominal discharge current (In)	:	15 kA
Voltage protection level (Up)	:	5,0 kV
Plug-in module	:	DG MOD H PV 750 (952049)

TESTS

Test requirements
EN 61643-31:2019

Test result
The test results are documented in DEKRA test file 227569600.

Conclusion
The examination has confirmed that all requirements were met.

Factory location
Dehn SE
Am Ludwigskanal 1
92360 Mühlhausen, Germany