CERTIFICATE

Issued to:
Applicant:
DEHN SE
Hans-Dehn-Str. 1
92318 Neumarkt, Germany

Licensee:
DEHN SE
Hans-Dehn-Str. 1
92318 Neumarkt, Germany

Product	:	Surge Protective Devices
Trade name(s)	:	DEHN
Type(s)/model(s)	:	DGP M 255 and DGP M 255 FM

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
- a type test according to the standard(s) EN 61643-11:2012 and EN 61643-11:2012/A11:2018
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 961720

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 23 February 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-127456

DEKRA Certification B.V.

B.T.M. Holtus
Managing Director

H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL

PRODUCTS
RvA C 001

KEMA KEUR

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra.nl Company registration 09085396

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	Surge Protective Devices
Trade name(s)	:	DEHN
Type(s)/model(s)	:	DGP M 255 and DGP M 255 FM
SPD type/class	:	1/I 2/II
Maximum continuous operating voltage (Uc)	:	255 Vac
Nominal discharge current (In)	:	100 kA
Impulse discharge current (Iimp)	:	100 kA
Voltage protection level (Up)	:	≤ 1,5 kV
Plugin module	:	961010

Product data – type DGP M 255

Part No.	:	961101

Product data – type DGP M 255 FM

Part No.	:	961105

TESTS

Test requirements

EN 61643-11:2012
EN 61643-11:2012/A11:2018

Test result

The test results are laid down in DEKRA test file 226947200.

Additional information

This certificate replaces certificate No. 71-122883 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

The factory location is registered with the number 164748.