# Certificate

## No.: 968/FSP 2849.00/25

| | | | |
|---|---|---|---|
| **Product tested** | Safety Relais as Contact Extension | **Certificate holder** | Carlo Gavazzi Industri A/S<br>Over Hadstenvej 40<br>8370 Hadsten<br>Denmark |
| **Type designation** | SME41 | | |
| **Codes and standards** | EN ISO 13849-1:2023 | | |
| **Intended application** | The devices comply with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1) and can be used in applications up to these safety integrity levels.<br>In order to achieve Cat. 4 and PL e in accordance with EN ISO 13849-1, it is necessary to monitor the device with a master safety module that corresponds to Cat. 4 and PL e in accordance with EN ISO 13849-1. | | |
| **Specific requirements** | The instructions of the associated Installation and Operating Manual shall be considered. | | |

Valid until 2030-01-17

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V3.0:2020 in its actual version, whose results are documented in Report No. 968/FSP 2849.00/25 dated 2025-01-16. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-00.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2025-01-17

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Gebhard Bouwer

www.fs-products.com
www.tuv.com

TÜVRheinland®
Precisely Right.

10/222 12. 12 E A4 ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.

TÜV Rheinland Industrie Service GmbH, Am Grauen Stein, 51105 Köln / Germany
Tel.: +49 221 806-1790, Fax: +49 221 806-1539, E-Mail: industrie-service@de.tuv.com