中国国家强制性产品认证证书

证书编号：2024010303690918

认证委托人名称及地址

Carlo Gavazzi Automation SpA
Via Milano,13 20020-Lainate(MI)-Italy

生产者名称及地址

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

生产企业名称及地址

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

产品名称和系列、型号、规格

三相继电器
DPA01,DPA02,DPB01,DPB02:
Ui:250V;Uimp:4kV;AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC24V/2.5A;DC-12:Ue/Ie:DC24V/5A;Ith:8A；IP20；具体型号解释见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则　低压电器　低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 09 月 11 日　　**有效期至：**2029 年 09 月 10 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010303690918

DPxyykzzz
x = A or B
A= max 1 front knob. OP-amp based 1 个前按键或基于 amp
B = 0,1 or 2 or more front knobs. Microcontroller based 0,1 或 2 或更多前按键，微控制
yy = Housing and function = 01 or 02 外壳和功能
01= phase loss/asymmetry/sequence 失相/不对称/相序
02= phase sequence or multifunction 相序或多功能
k = Number of output contacts= C or D 触点数量
C= 1 SPDT relay
D= 2 SPDT relays or 1 DPDT relay
zzz = Operational voltage = M23 or M44 or M48 or M60 or M69 工作电压
M23: 208~240V
M40: 380~415V
M44: 208~480V
M48: 380~480V
M60: 380~600V
M69: 600~690V

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010303690918

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Automation SpA
Via Milano,13 20020-Lainate(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

NAME AND LOCATION OF THE FACTORY

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

PRODUCT NAME,MODEL AND SPECIFICATION

3-phase Relay
DPA01,DPA02,DPB01,DPB02：
Ui:250V;Uimp:4kV;AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC24V/2.5A;DC-12:Ue/Ie:DC24V/5A;
Ith:8A；IP20；See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.11,2024 **Valid until:** Sep.10,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

中国质量认证中心有限公司 11010610269466

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010303690918

Appendix: Page 1 of 1

DPxyykzzz
x = A or B
A= max 1 front knob. OP-amp based 1 个前按键或基于 amp
B = 0,1 or 2 or more front knobs. Microcontroller based 0,1 或 2 或更多前按键，微控制
yy = Housing and function = 01 or 02 外壳和功能
01= phase loss/asymmetry/sequence 失相/不对称/相序
02= phase sequence or multifunction 相序或多功能
k = Number of output contacts= C or D 触点数量
C= 1 SPDT relay
D= 2 SPDT relays or 1 DPDT relay
zzz = Operational voltage = M23 or M44 or M48 or M60 or M69 工作电压
M23: 208~240V
M40: 380~415V
M44: 208~480V
M48: 380~480V
M60: 380~600V
M69: 600~690V

This page is attached to the certificate and should be used at the same time as the certificate page.