中国国家强制性产品认证证书

证书编号：2024010303690914

认证委托人名称及地址

Carlo Gavazzi Automation SpA
Via Milano,13 20020-Lainate(MI)-Italy

生产者名称及地址

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

生产企业名称及地址

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

产品名称和系列、型号、规格

三相继电器
DPB01,DPB02(型号解释详见附页); Uimp:4kV; Ith: 8A; Ui:250V; Ue/Ie: AC-15:AC250V/2.5A; DC-12: DC24V/5A; DC-13:DC24V/2.5A; IP20

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则　低压电器　低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 09 月 11 日　**有效期至：**2029 年 09 月 10 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010303690914

DPByykzzzabbcccc

yy: Housing and function

01= phase sequence/phase loss/undervoltage/overvoltage

02= phase sequence/phase loss/asymmetry

k:Number of output contacts

C= 1 SPDT relay

zzz: Operational voltage

M23= 208~240V

M44= 208~480V

M48= 380~480V or 380~415V

a: optional

N= without phase sequence detection

bb: optional

W4= segnalation loads application

cccc: optional

up to four alphanumerical characters indicating cosmetic variations, not affecting safety

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010303690914

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Automation SpA
Via Milano,13 20020-Lainate(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

NAME AND LOCATION OF THE FACTORY

Carlo Gavazzi Controls SPA
Via Safforze,8,32100 BELLUNO Italy

PRODUCT NAME,MODEL AND SPECIFICATION

3-phase Relay
DPB01, DPB02; Uimp:4kV; Ith: 8A; Ui:250V; Ue/Ie: AC-15:AC250V/2.5A; DC-12: DC24V/5A; DC-13:DC24V/2.5A; IP20

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.11,2024 **Valid until:** Sep.10,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010303690914

DPByykzzzabbcccc

yy: Housing and function

01= phase sequence/phase loss/undervoltage/overvoltage

02= phase sequence/phase loss/asymmetry

k:Number of output contacts

C= 1 SPDT relay

zzz: Operational voltage

M23= 208~240V

M44= 208~480V

M48= 380~480V or 380~415V

a: optional

N= without phase sequence detection

bb: optional

W4= segnalation loads application

cccc: optional

up to four alphanumerical characters indicating cosmetic variations, not affecting safety

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666