本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010304690278

NAME AND ADDRESS OF THE APPLICANT

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND ADDRESS OF THE MANUFACTURER

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

NAME AND LOCATION OF THE FACTORY

Carlo Gavazzi Ltd.
BLB 042, Bulebel Industrial Estate, Zejtun, ZTN3000, Malta

PRODUCT NAME,MODEL AND SPECIFICATION

Motor Softstarter

RSBT,RSBD,RSWT；Ui: RSBT, RSBD:690V, RSWT40:630V, RSWT60 :690V; Uimp:4kV;Ue: RSBT, RSDT:AC220-480V, RSWT40:AC220-400V, RSWT60:AC220-600V;RSBT...55..., RSBD...55... Ith= Ie:55A；RSBT...70..., RSBD...70... Ith= Ie:70A；RSBT...95..., RSBD...95... Ith= Ie:95A；RSWT...70...Ith= Ie:70A；RSWT...90...Ith= Ie:90A；Levels of Protection：IP20; Utilization Category：AC-53b; Poles：3P.See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.10,2024 **Valid until:** Sep.09,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304690278

NOMENCLATURE BREAKDOWN AND RATINGS FOR RSBT 120MM Series:

RSB	T	48	95	C	V0	XXXX
I	II	III	IV	V	VI	VII

I -
Designated basic series:
RSB – Compressor Softstarter

II -
Construction Type:
D – 3 Phase Compressor, 2-pole switching
T – 3 Phase Compressor, 3-pole switching

III -
Rated Operational Voltage:
48 – 220-480 Vac (+10% / -15%)

IV -
Nominal IEC current rating
55 – max. 55 A
70 – max. 70 A
95 – max. 95 A

V -
Control Voltage:
C – 24 V ac/V dc (+10% / -10%), 110÷400 V ac (+10% / -15%)

VI
Options:
V0 – 2 x Changeover relay outputs
VC – 2 x Changeover relay outputs + Modbus

VII -
Function (optional):
xxxx – Special function
Blank – Standard function

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304690278

NOMENCLATURE BREAKDOWN AND RATINGS FOR RSWT 75MM Series:

RSW	T	60	90	G	G	V1	1	1	C	XXX
I	II	III	IV	V	VI	VII	VIII	IX	X	XI

I - Designated basic series:
RSW – Pump Softstarter

II - Construction Type:
T – 3 Phase Compressor, 3-pole switching

III - Rated Operational Voltage:
40 – 220-400 Vac (+10% / -15%)
60 – 220-600 Vac (+10% / -15%)

IV - Nominal IEC current rating
70 – max. 70 A
90 – max. 90 A

V - Control Voltage:
E – 110-400 V ac (+10% / -15%)
F – 24 V ac/V dc (+10% / -10%)
G – 100-240 V ac (+10% / -15%)

VI External Supply Voltage:
0 – Not required (for Control Voltage “E” and “F” digit)
F - 24 V ac/V dc (+10% / -10%) (for Control Voltage “F” digit only)
G – 100-240 Vac (+10% / -15%) (for Control Voltage “G” digit only)

VII - Options:

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304690278

V0 – No Overload protection
V1 – With Overload protection

VIII Options:
1 – With PTC
0 – No PTC

IX Options:
1 – With Fan
Blank – No Fan

X Communication (optional):
C – Communication
Blank – No Communication

XI Function (optional):
xxxx – Special function
Blank – Standard function

This page is attached to the certificate and should be used at the same time as the certificate page.